

&	AND	HB	HOSE BIBB
∠	ANGLE	HC	HANDICAPPED
⊙	AT	HD	HEAD
⊕	CENTER LINE	HDWE	HARDWARE
⊖	PROPERTY LINE	HI	HIGH
⊗	DIAETER or ROUND	HORIZ	HORIZONTAL
⊘	EXISTING	HP	HIGH PRESSURE
(N)	NEW	HR	HOUR
⊥	PERPENDICULAR	HT	HEIGHT
#	POUND or NUMBER	HVAC	HEATING, VENTILATING, AIR CONDITIONING
A/C	AIR CONDITIONING		
AP	ACCESS PANEL	ID	INSIDE DIAMETER (DIM.)
ADJ.	AIR DRAIN	INSUL	INSULATION
ADJ.	ADJUSTABLE	INT	INTERIOR
ADMIN	ADMINISTRATION	IW	IRIGATION WATER
AGGR	AGGREGATE		
AL	ALUMINUM		
APPROX	APPROXIMATE	LAV	LAVATORY
APPT	APPOINTMENTS	LPF	LIQUID PETROLEUM GAS
ARCH.	ARCHITECTURAL		
ASB	ASBESTOS	M	MEN
ASPH	ASPHALT	MACH	MACHINE
ASST	ASSISTANT	MATL	MATERIAL
AUTO.	AUTOMATIC	MECH	MECHANICAL
		MS	MORT SINK
		MTL	METAL
BD	BOARD	MGR	MANUFACTURER
(BF)	BELOW FINISH FLOOR	MH	MANHOLE
(BG)	BELOW FINISH GRADE	MIN	MINIMUM
BLDG	BUILDING	MISC	MISCELLANEOUS
BLKG	BLOCKING	MONIT	MONITOR
BM	BEAM		
BOT	BOTTOM		
BV	BALL VALVE		
		N	NORTH
CB	CATCH BASIN	NIC	NOT IN CONTRACT
CD	CONDENSATE DRAIN	NO. or #	NUMBER
CEM	CEMENT	NOM	NOMINAL
CER	CERAMIC	NTS	NOT TO SCALE
CI	CAST IRON		
CJ	CONCRETE JOINT		
CLG	CEILING	OAV	OVERALL
CLKG	CAULKING	OAO	OXYGEN, AIR & VACUUM
CLR	CLEAR	OC	ON CENTER
CO	CLEANOUT	OVHD	OVERHEAD
COL	COLUMN	OX.	OXYGEN
COMP	COMPRESSED		
CONC	CONCRETE	PTN	PARTITION
CONF	CONFERENCE	PHYS	PHYSICAL
CONN	CONNECTION	PR	PRESSURE REGULATOR
CONSTR	CONSTRUCTION	PVC	POLY-VINYL CHLORIDE PIPE
CONT	CONTINUOUS	PLAS	PLASTER
CORR	CORRIDOR	PLYWD	PLYWOOD
COTG	CLEANOUT TO GRADE	POIC	POINT OF CONNECTION
CP	CIRCULATING PUMP	PREFAB	PREFABRICATED
CKS	COUNTERSINK	PREP	PREPARATION
CTR	CENTER	PT	PLUGGED TEE
CV	CHECK VALVE	PW	PROCESSED WATER
DBL	DOUBLE	R	RISER
DCW	DOMESTIC COLD WATER	RAD.	RADIUS
DEPT	DEPARTMENT	RD	ROOF DRAIN
DET	DETAIL	REF	REFERENCE
DF	DRINKING FOUNTAIN	REINF	REINFORCED
DHW	DOMESTIC HOT WATER	RQD	REQUIRED
DHWR	DOMESTIC HOT WATER RETURN	RWL	RAINWATER LEADER
DIA or ∅	DIAMETER		
DIR	DIRECTOR		
DN	DOWN		
DR	DOOR	S	SINK or SOUTH
DS	DOWNSPOUT	SA	WATER ARRESTER
DSP	DRY STANDPIPE	SB	SPLASH BLOCK
DTW	DOMESTIC TEMPERED WATER	SCHD	SCHEDULE
DWG	DRAWING	SOL	STORM DRAIN LINE
		SECT.	SECTION
E	EAST	SH	SHOWER
EA	EACH	SH	SHEET
EDF	ELECTRIC DRINKING FOUNTAIN	SM	SIMILAR
EL	ELECTRICAL	SL	SINKRINK LINE
ELEV	ELEVATION	SPEC	SPECIFICATION
EMER	EMERGENCY	SST	SHUT-OFF VALVE
ENCLOS.	ENCLOSURE	S	SEWER SINK
EO	ELECTRICAL OUTLET	SSV	STAINLESS STEEL
EP	ELECTRICAL PANEL	STD	STANDARD
EQ	EQUAL	STL	STEEL
EQUIP	EQUIPMENT	STR	STORAGE
(E)	EXISTING	STRUCT	STRUCTURAL
EXP.	EXPANSION	SUPV	SUPERVISOR
EXP.	EXPOSED	SUSP	SUSPENDED
EXT	EXTERIOR	S&W	SOIL & WASTE
FA	FIRE ALARM	TC	TOP OF CURB
FCO	FLOOR CLEANOUT	TEL	TELEPHONE
FD	FLOOR DRAIN	TER	TERAZZO
FDN	FOUNDATION	THK	THICK
FE	FIRE EXTINGUISHER	TCC	TOP OF CONCRETE
FEC	FIRE EXTINGUISHER CABINET	TP	TRAP PRIMER
FE	FIRE HYDRANT	TRANS	TRANSCRIPTION
FHO	FIRE HOSE CAB.	TREAT.	TREATMENT
FHMS	FLAT HEAD METAL SCREW	TYP	TYPICAL
FIN.	FINISH	TV	TEMPERING VALVE
FL	FLOOR		
FLASH.	FLASHING		
FM	FIRE MAIN	UL	UNDERWRITERS LABORATORY
FOC	FACE OF CONCRETE	UON	UNLESS OTHERWISE NOTED
FOF	FACE OF FINISH	URINAL	URINAL
FR	FRAME		
FRPF	FIREPROOFING	V	VENT
FS	FLOOR SINK	VA	VALVE
FSH	FIRE SPRINKLER HEAD	V	VENT
FSL	FIRE SPRINKLER LINE	VTR	VENTRIFIED CLAY
FTR	FLUE THRU ROOF	VVC	VENT THRU ROOF
FUNC	FUNCTION	VO	VENT OFFSET
FURR	FURRING		
FUT	FUTURE	W	WASTE LINE
		W/	WITH
GA	GAUGE	WC	WATER CLOSET
GALV	GALVANIZED	WCO	WALL CLEANOUT
GEN	GAS COCK	WH	WATER HEATER
GEN	GENERATOR	WHA	WATER HAMMER ARRESTOR
GI	GALVANIZED IRON	W/O	WITHOUT
GL	GLASS	WMF	WASHING MACHINE FITTING

SYMBOL	DESCRIPTION
	BALL VALVE
	BRANCH TOP CONNECTION
	BRANCH BOTTOM CONNECTION
	CAPPED PIPE
	CHECK VALVE
	CLEANOUT
	CLEANOUT TO GRADE
	CIRCULATING PUMP
	CONDENSATE DRAIN
	CONDENSATE "P" TRAP
	DOMESTIC COLD WATER
	DOMESTIC HOT WATER
	DOMESTIC HOT WATER RETURN
	EXISTING WASTE OR SOIL & WASTE
	FIRE HYDRANT
	FLOOR CLEANOUT
	FLOOR SINK
	GAS
	GAS COCK
	GAS PRESSURE REGULATOR
	GATE VALVE
	HOSE BIBB
	PIPE RISER (ELBOW)
	PIPE DROP (ELBOW)
	PIPE DROP OR RISER
	POINT OF CONNECTION
	PROCESS WASTE
	SHUT-OFF VALVE
	SHUT-OFF VALVE IN YARDBOX
	SOIL & WASTE
	TRAP PRIMER
	VENT
	VENT OFFSET
	VENT THRU ROOF
	WALL CLEANOUT
	WASTE
	WATER HAMMER

<p>SECTION 1</p> <p>BASIC MECHANICAL MATERIALS AND METHODS</p>	<p>1.12 PERMITS AND FEES</p> <p>A. OBTAIN, PAY FOR, AND DELIVER PERMITS, CERTIFICATION OF INSPECTION, AND OTHER SUCH ITEMS REQUIRED BY THE AUTHORITIES HAVING JURISDICTION. DELIVER CERTIFICATION TO THE CONSTRUCTION MANAGER PRIOR TO FINAL ACCEPTANCE OF THE WORK. AN INSPECTION CERTIFICATE FOR EACH CLASS OF WORK REQUIRING INSPECTION MUST BE SUBMITTED PRIOR TO OR WITH THE FINAL PAYMENT INVOICE. THE RESPONSIBLE TRADE CONTRACTOR MUST MAKE APPLICATION FOR THE INSPECTION, COORDINATE SAME AND PAY THE REQUIRED INSPECTION FEE.</p> <p>1.13 EXTENDED WARRANTIES</p> <p>A. WORK FURNISHED UNDER THE CONTRACT SHALL BE WARRANTED AGAINST DEFECTS IN WORKMANSHIP AND ( CONTRACTOR FURNISHED) MATERIALS FOR A PERIOD OF NOT LESS THAN ONE (1) YEAR, OR AS OTHERWISE SPECIFIED, FROM THE DATE OF FINAL ACCEPTANCE OF THE INSTALLATION. DEFECTS OF WORKMANSHIP DEVELOPING DURING THIS PERIOD SHALL BE REMEDIED, AND DEFECTIVE MATERIAL REPLACED, WITHOUT ADDITIONAL COST. WHEN DEFECTS IN A TRADE CONTRACTOR'S WORK CAUSES DAMAGE TO THE WORK OF THE OTHER TRADE CONTRACTORS, SUCH DAMAGE SHALL BE REPAIRED BY THE TRADE CONTRACTOR CAUSING DAMAGE AND WORK RESTORED TO ITS ORIGINAL CONDITION, AT THE EXPENSE OF THE TRADE CONTRACTOR THAT CAUSED THE DAMAGE.</p>	<p>B. SOIL, WASTE, AND VENT PIPING ABOVE FLOOR: STANDARD WEIGHT COATED CAST IRON PIPE AND STAINLESS STEEL/ NEOPRENE GASKET FITTING, OR A.B.S. OR P.V.C. SCHEDULE 40, AS APPROVED BY LOCAL AUTHORITY IN CONCEALED LOCATIONS.</p> <p>C. HOT &amp; COLD WATER PIPING ABOVE FLOOR: TYPE "L" COPPER, HARD DRAWN. BELOW GROUND OUTSIDE OF BUILDING: TYPE "K" SOFT DRAWN COPPER TUBING WITH OUT JOINTS.</p>
<p>PART 1 – GENERAL</p> <p>1.1 SUMMARY</p>	<p>A. LABOR, MATERIALS, TOOLS, AND SERVICES FOR A COMPLETE INSTALLATION OF EQUIPMENT AND SYSTEM CONTAINED IN THE CONTRACT DOCUMENTS.</p> <p>B. PRINCIPAL FEATURES OF THE WORK INCLUDED ARE:</p> <ol style="list-style-type: none"> <li>PLUMBING SYSTEM AND RELATED PIPING INSULATION.</li> <li>DOMESTIC WATER PIPING, VALVES, CONNECTIONS AND RELATED PIPING INSULATION.</li> <li>LIMITED AREA FIRE PROTECTION (SPRINKLER SYSTEMS).</li> <li>EXCAVATING AND BACKFILLING FOR MECHANICAL WORK; COORDINATE WITH APPROPRIATE TRADE.</li> <li>ANCHOR BOLTS, SLEEVES, SUPPORTS AND SIMILAR ITEMS TO BE BUILT INTO CONCRETE OR MASONRY.</li> <li>PREPARATION AND SUBMITTAL OF SHOP DRAWING AND PRODUCT DATA.</li> <li>MAINTAINING A RECORD SET OF BLUE LINE PRINTS AND MAKING THEM TO INDICATE LOCATIONS OF CONCEALED ITEMS, AND DEVIATIONS MADE TO SUIT CONDITIONS AND PRODUCTION OF MECHANICAL AS–BUILT (RECORD) DRAWINGS.</li> </ol>	<p>D. CONDENSATE DRAIN PIPING: TYPE "M" COPPER WITH 95–5 TIN ANTIMONY SOLDER AND WROUGH COPPER FITTINGS OR</p> <p>E. INDIRECT WASTE PIPING: TYPE "M" COPPER WITH 95–5 TIN ANIMONY SOLDER AND WROUGHT COPPER FITTINGS OR P.V.C. SCHEDULE 40, AS APPROVED BY LOCAL AUTHORITY.</p>
<p>1.2 JOB CONDITIONS.</p> <p>A. SUBMITTAL OF BID IMPLIES BIDDER HAS READ APPLICABLE PARAGRAPHS OF THE SPECIFICATIONS AND WILL BE BOUND BY THEIR CONDITIONS.</p>	<p>1.3 LOCAL CONDITIONS</p> <p>A. CONFORM WITH LOCAL CONDITIONS. COORDINATE WITH LOCAL UTILITIES ON SIZE OF UTILITY SERVICE.</p>	<p>F. UNDERGROUND GAS PIPING: SCHEDULE 40 BLACK STEEL PIPE WITH LONG RADIUS STEEL WELDING FITTINGS INCLUDING CATHOLIC PROTECTION OR POLYETHYLENE AS APPROVED BY LOCAL GAS COMPANY AND AUTHORITY HAVING JURISDICTION. INSTALLATION OF GAS SERVICE PIPING IN VENTED CONDUIT AND MEETING WITH THE LOCAL GAS COMPANY'S APPROVAL.</p>
<p>1.4 INTENT</p> <p>A. THE CONTRACT DOCUMENTS (DRAWINGS AND SPECIFICATIONS) DESCRIBE THE PLUMBING WORK OF THIS PROJECT ANY ITEMS MENTIONED IN ONE PART SHALL BE AS BINDING AS THOUGH MENTIONED IN BOTH.</p>	<p>2.1 MATERIALS AND EQUIPMENT</p> <p>A. WITHIN THE CONTRACT DOCUMENTS RELATING TO PLUMBING WORK, MANUFACTURER'S NAMES, CATALOG NUMBERS, AND OTHER PROPRIETARY REFERENCES ARE MADE. SUCH REFERENCES ARE MADE TO ESTABLISH THE STANDARDS OF QUALITY AND TYPE REQUIRED, AND NOT TO LIMIT COMPETITION. ACCEPTABLE MANUFACTURER'S OF COMPETITIVE PRODUCTS ARE LISTED IN APPLICABLE SECTIONS AS "APPROVED EQUALS". REASONABLE REQUESTS FOR SUBSTITUTION OR ADDITIONS TO "APPROVED EQUALS" WILL BE CONSIDERED, BUT THE MECHANICAL ENGINEER WILL BE THE SOLE JUDGE OF ACCEPTABILITY OF ITEMS PROPOSED AS SUBSTITUTES.</p>	<p>G. GAS PIPING ABOVE GROUND: SCHEDULE 40 BLACK STEEL WITH 125 POUND BLACK MALLEABLE IRON SWEWED FITTINGS. GAS PIPING COMPOUND AT JOINTS IN COMPLIANCE WITH NFPA BULLETIN #45 AND LOCAL APPLICABLE CODES AND SUITABLE FOR NATURAL GAS SERVICE. INSTALL MOISTURE TRAPS ON HVAC UNITS, WATER HEATERS, AND KITCHEN EQUIPMENT</p>
<p>1.5 DEVIATIONS</p> <p>A. NO DEVIATIONS FROM SPECIFICATIONS AND DRAWINGS SHALL BE MADE WITHOUT FULL KNOWLEDGE AND WRITTEN CONSENT OF CONSTRUCTION MANAGER.</p>	<p>3.1 LOCATIONS</p> <p>A. PLUMBING LAYOUTS INDICATED ON DRAWINGS ARE DIAGRAMMATIC. EXACT LOCATIONS OF PIPES, AND EQUIPMENT MAY VARY BECAUSE OF CONFLICTS WITH WORK OF OTHER TRADES. WORK OUT CONFLICTS WHERE RELOCATION'S WILL NOT AFFECT OPERATION OR APPEARANCE OF SYSTEMS.</p>	<p>H. STORM PIPING BELOW GROUND: STANDARD WEIGHT COATED CAST IRON PIPE AND STAINLESS STEEL/ NEOPRENE GASKET FITTING, OR A.B.S. OR P.V.C. SCHEDULE 40, AS APPROVED BY LOCAL AUTHORITY IN CONCEALED LOCATIONS.</p>
<p>1.6 QUALITY ASSURANCE</p> <p>A. COMPLY WITH APPLICABLE LOCAL, STATE AND FEDERAL CODES.</p>	<p>3.2 UTILITIES EXCAVATING AND BACKFILLING</p> <p>A. PERFORM TRENCHING, EXCAVATING, BACKFILLING FOR PLUMBING WORK IN ACCORDANCE WITH THE APPROPRIATE SECTIONS AND AS SET FORTH BELOW</p> <ol style="list-style-type: none"> <li>PERFORM WORK NECESSARY FOR INSTALLATION OF PLUMBING UTILITIES.</li> <li>DEPTH OF EXCAVATION TO PROVIDE A MINIMUM OF 3" ABOVE TOP OF PIPE. EXCAVATION TO BE CARRIED TO A DEPTH OF AT LEAST 6" BELOW BOTTOM OF PIPE ELEVATION. FILL BELOW PIPE (6") AROUND PIPE, AND A MINIMUM OF 12" ABOVE PIPE WITH SAND OR CLASS "B" CRUSHED STONE TAMPED FIRM AND EVEN. SEPARATE TOPSOIL DURING EXCAVATION. FINAL LAYER OR DIRT (12" MINIMUM) TO BE TOPSOIL. TRENCHES TO BE AT LEAST 18" WIDER THAN PIPE WITH BATTER BOARDS PLACED EVERY 25". BACKFILLING SHALL BE DONE TO EXCLUDE USE OF ROCK OR STONE ABOVE SAND OR CRUSHED STONE.</li> </ol>	<p>I. STORM PIPING ABOVE GROUND: STANDARD WEIGHT COATED CAST IRON PIPE AND STAINLESS STEEL/ NEOPRENE GASKET FITTING, OR A.B.S. OR P.V.C. SCHEDULE 40, AS APPROVED BY LOCAL AUTHORITY.</p>
<p>1.7 CODES AND STANDARDS</p> <p>A. PERFORM WORK SPECIFIED IN DIVISION 15 IN ACCORDANCE WITH THE APPLICABLE CODES AND STANDARDS LISTED BELOW, AND SUCH STANDARDS THAT MAY BE SPECIFIED IN OTHER SECTIONS, WHEN THESE SPECIFICATIONS ARE MORE STRINGENT, THEY TAKE PRECEDENCE. IN CASE OF CONFLICT, OBTAIN A DECISION FROM THE PLUMBING ENGINEER.</p>	<p>3.3 CUTTING AND PATCHING</p> <p>A. REPAIR OR REPLACE ROUTINE DAMAGE CAUSED BY CUTTING IN PERFORMANCE OF CONTRACT.</p> <p>B. PERFORM REPAIRS WITH MATERIALS WHICH MATCH EXISTING AND INSTALL IN ACCORDANCE WITH THE APPROPRIATE SECTION OF THESE SPECIFICATIONS OR THE BEST STANDARDS OF THE INDUSTRY.</p>	<p>J. TRAPS AND VENTS FOR SERVICE SINK: A.B.S. OR P.V.C. SCHEDULE 40, AS APPROVED BY LOCAL AUTHORITY.</p>
<p>1.8 COORDINATION</p> <p>A. CAREFULLY EXAMINE SPECIFICATIONS AND DRAWINGS TO BE THOROUGHLY FAMILIAR WITH ITEMS WHICH REQUIRE PLUMBING AND COORDINATION.</p>	<p>3.4 CONNECTION TO EQUIPMENT</p> <p>A. CONNECT OR INSTALL EQUIPMENT SHOWN ON MECHANICAL DRAWINGS THAT REQUIRE PLUMBING</p> <ol style="list-style-type: none"> <li>ROUGH – IN PIPING AND CONNECT EQUIPMENT</li> <li>PROVIDE PIPING, SHUTOFF VALVES, AND UNIONS REQUIRED FOR A COMPLETE INSTALLATION,</li> </ol>	<p>K. ALL FIXTURES: AS INDICATED ON DRAWINGS WITH EQUAL PRODUCTS FURNISHED BY AMERICAN STANDARD, KOHLER, ELIER OR EQUAL.</p>
<p>1.9 SUBMITTALS</p> <p>A. SUBMITTALS ARE ONLY REQUIRED FOR SPECIFIC ITEMS OF EQUIPMENT OR MATERIAL LISTED IN INDIVIDUAL SECTIONS OF THESE SPECIFICATIONS.</p>	<p>3.5 SERVICE OF SYSTEM</p> <p>A. EMPLOY COMPETENT, QUALIFIED PERSONNEL IN OPERATION OF THE EQUIPMENT.</p> <p>B. PROVIDE FOR PROPER OPERATION AND CLEANLINESS.</p>	<p>L. INSULATE ALL HOT AND COLD WATER COPPER PIPING WITH AT LEAST 1/2" THICK FOAM RUBBER OR FOAM PLASTIC TYPE PIPE INSULATION</p>
<p>1.10 DELIVERY AND STORAGE</p> <p>A. INsofar AS POSSIBLE, DELIVER ITEMS IN MANUFACTURER'S ORIGINAL UNOPENED PACKAGING, WHERE THAT IS NOT PRACTICAL, COVER ITEMS WITH PROTECTIVE MATERIALS TO KEEP THEM FROM BEING DAMAGED. USE CARE IN LOADING, TRANSPORT, UNLOADING, AND STORAGE TO KEEP ITEMS FROM BEING DAMAGED.</p>	<p>PART 2 – PRODUCTS</p> <p>2.1 DESCRIPTION</p> <p>A. SOIL, WASTE, AND VENT PIPING BELOW FLOOR TO 5'–0" OUTSIDE BUILDING: STANDARD WEIGHT COATED CAST IRON SOIL PIPE AND CAST IRON/ NEOPRENE GASKET FITTINGS. YARD PIPING, PIPE AND FITTINGS: A.B.S. OR P.V.C. SCHEDULE 40 PIPE AND FITTINGS MAY BE INSTALLED, AS APPROVED BY LOCAL AUTHORITY IN CONCEALED LOCATIONS ONLY. EXCEPTION: ALL SOIL, WASTE &amp; VENTS LOCATED WITHIN A FIRE RATED WALL SHALL BE METALLICS(STEEL, CAST IRON ECT., NO PVC) IT SHALL BE THE RESPONSIBILITY OF THE PLUMBER TO VERIFY ALL FIRE RATED WALLS &amp; CONSTRUCTION AS SHOWN ON THE ARCHITECTURAL DRAWINGS &amp; COORDINATE WITH THE GENERAL CONTRACTOR</p>	<p>M. ALL FIXTURES: GRADE A, WHITE.</p> <p>C. EXPOSED PIPING TO FIXTURES: A PRODUCT OF THE FIXTURE MANUFACTURE.</p>
<p>1.11 FIRE RATINGS</p> <p>A. MATERIALS USED ANYWHERE IN THE WORK MUST HAVE NFPA RATINGS AS FOLLOWING:</p> <ol style="list-style-type: none"> <li>FLAME SPREAD – NOT OVER 25</li> <li>SMOKE DEVELOPED – NOT OVER 50</li> <li>FUEL CONTRIBUTED – NOT OVER 25</li> </ol>	<p>PART 3 – EXECUTION</p> <p>3.1 LOCATIONS</p> <p>A. PLUMBING LAYOUTS INDICATED ON DRAWINGS ARE DIAGRAMMATIC. EXACT LOCATIONS OF PIPES, AND EQUIPMENT MAY VARY BECAUSE OF CONFLICTS WITH WORK OF OTHER TRADES. WORK OUT CONFLICTS WHERE RELOCATION'S WILL NOT AFFECT OPERATION OR APPEARANCE OF SYSTEMS.</p>	<p>N. ALL ACCESSORIES, AS INDICATED ON DRAWING WITH EQUAL PRODUCTS FURNISHED BY WADE, JOSAM, OR ZURN BEING ACCEPTABLE.</p>
<p>1.12 PERMITS AND FEES</p> <p>A. OBTAIN, PAY FOR, AND DELIVER PERMITS, CERTIFICATION OF INSPECTION, AND OTHER SUCH ITEMS REQUIRED BY THE AUTHORITIES HAVING JURISDICTION. DELIVER CERTIFICATION TO THE CONSTRUCTION MANAGER PRIOR TO FINAL ACCEPTANCE OF THE WORK. AN INSPECTION CERTIFICATE FOR EACH CLASS OF WORK REQUIRING INSPECTION MUST BE SUBMITTED PRIOR</p>		

**SHEET**

**P-1**

**OF** **SHEET**